



Corporate Office
17522 Bothell Way Northeast
Bothell, Washington 98011
425.415.0551
www.riley-group.com

Project No: 2019-134
Report No: 137
RGI rep: Collin McCracken
Date: 7/28/2021 Wednesday
Page No. 1 of 1
Subject: Subgrade Observations Lots 13 & 14
Contractor:
Superintendent
Visitors:
Weather: Sunny

Permit No: SW18-00009
Project: Mallard Pointe
Location: SE 43rd Way and E Lk Sammamish SE, Issaquah
Client Name: Steve Burnstead Construction LLC
& Address: 11980 Northeast 24th Street, Suite 200
Bellevue, WA 98005

OBSERVATIONS:

As requested, a Riley Group representative visited the site today to observe and evaluate the following:

Contractor has excavated lots 13 and 14 to subgrade elevation. Subgrades were tested with a ½" steel tipped T-probe, and yielded less than ¼", indicating dense conditions suitable for the required bearing pressures.

RGI Rep sign: Collin McCracken
Reviewed by Kristina Weller

Copies To: _____
